

Ciências ULisboa

Faculdade
de Ciências
da Universidade
de Lisboa

DISCIPLINA MIEA 2019



Technologies of combustion


Corpo docente

Carla Silva (Teóricas e práticas) /Theory and practice
camsilva@ciencias.ulisboa.pt

P#10 Following table list the results of an experiment of boiler that is used to produce superheated vapour. The boiler is feed by natural gas trough a conventional burner.

- a) The air/fuel ratio
- b) The higher heating value of the fuel
- c) Heat transfer to water, assuming that heat loss trough boiler walls are 3% of the lower heating value.


Fuel rate	150 m³/h
Reactants temperature@ entrance	25°C
Products temperature @exit	227°C
Fuel composition by volume(%)	CH ₄ : 88 H ₂ : 2 CO ₂ : 3 N ₂ : 7
Dry analysis combustion products (%)	O ₂ : 1.1 CO ₂ : 10.8 N ₂ : 88.1




- Maximum heat release, $\max Q_{out}: T_{out}=T_{in}$
- Maximum flame temperature, T_{ad} :

$H_{reag}(T_{in})=H_{prod}(T_{ad})$ (constant pressure, e.g. Diesel engine, gas turbine, furnace)


$H_{reag}(T_{in})=H_{prod}(T_{ad})-R(n_{prod}T_{ad}-n_{reag}T_{in})$ (constant volume, e.g. gasoline engine)



- Ideal stoichiometric combustion



- Real stoichiometric combustion



K is tabulated as a function of temperature for different equilibrium reactions




**APÊNDICE 4
CONSTANTES DE EQUILÍBRIO**

$H_2 + 1/2 O_2 \rightleftharpoons H_2O$
 $CO + 1/2 O_2 \rightleftharpoons CO_2$
 $CO_2 + H_2 \rightleftharpoons CO + H_2O$
 $OH + 1/2 H_2 \rightleftharpoons H_2O$
 $1/2 O_2 + 1/2 N_2 \rightleftharpoons NO$
 $2H \rightleftharpoons H_2$
 $2O \rightleftharpoons O_2$
 $2N \rightleftharpoons N_2$


$\log_{10} K_p$ com as pressões parciais em atmosferas



T (K)	$\frac{P_{H_2O}}{P_{H_2} \sqrt{P_{O_2}}}$	$\frac{P_{CO_2}}{P_{CO} \sqrt{P_{O_2}}}$	$\frac{(P_{H_2O})(P_{CO})}{(P_{H_2})(P_{CO_2})}$	$\frac{P_{H_2O}}{P_{OH} \sqrt{P_{H_2}}}$	$\frac{P_{NO}}{\sqrt{P_{O_2}} \sqrt{P_{N_2}}}$	$\frac{P_{H_2}}{(P_H)^2}$	$\frac{P_{O_2}}{(P_O)^2}$	$\frac{P_{N_2}}{(P_N)^2}$
298	40,048	45,066	-5,018	46,181	-15,171	71,232	81,202	159,600
300	39,786	44,760	-4,974	45,876	-15,073	70,762	80,664	158,578
400	29,240	32,431	-3,191	33,600	-11,142	51,758	58,944	117,408
600	18,633	20,087	-1,454	21,264	-7,210	32,676	37,146	76,162
800	13,289	13,916	-0,627	15,060	-5,243	23,082	26,202	55,488
1000	10,062	10,221	-0,159	11,322	-4,062	17,294	19,612	43,056
1200	7,899	7,764	0,135	8,822	-3,275	13,416	15,208	34,754
1400	6,347	6,014	0,333	7,030	-2,712	10,632	12,054	28,812
1600	5,180	4,706	0,474	5,686	-2,290	8,534	9,684	24,350
1800	4,270	3,693	0,577	4,638	-1,962	6,896	7,836	20,874
2000	3,540	2,884	0,656	3,799	-1,699	5,582	6,356	18,092
2200	2,942	2,226	0,716	3,113	-1,484	4,504	5,142	15,810
2400	2,443	1,679	0,764	2,541	-1,305	3,602	4,130	13,908

Tabela A4.1
 Constantes de equilíbrio. (Dados extraídos de Rogers e Mayhew, 1994.) (continua)





More rpm, less combustion time!!!






ppm 😊 !!!!



© 2007 Encyclopædia Britannica, Inc.


$$\phi = \frac{1}{\lambda}$$

How to control combustion to lower at least NOx emissions?




EGR-Exhaust gas recirculation

Water injection




c) Injecção de água ou vapor de água




d) Estagiamento do ar de combustão


Air introduction in 2 stages



Air introduction in 2 stages
+fuel introduction in 2 stages





Poor pre-mixtures




"Reburning"
 +Non-catalytic Selective NOx reduction

Coal fire power-plants – NO_x control- SNCR- Selective non Catalytic Reduction





Adiabatic Flame Temperature




No pre-mixture

Diesel Combustion Process




Influence of ignition delay on emissions




No pre-mixture


Diesel Combustion Process



Visible particles





Influence of ignition delay on emissions



No pre-mixture

Diesel Combustion Process



Influence of ignition delay on emissions


CA-Crank angle (angulos de cambota)

BTDC-Before Top dead centre (antes do ponto morto superior)

Diesel Engine Emissions : formation, effect of variables and their control



HC emission from CI Engines

- Effect of nozzle sac volume and hole type



Influence of injector nozzle

U.S. Patent Aug. 15, 1978 Sheet 1 of 2 4,106,702




Particles and soot formation

PM1
PM2.5
PM10



- Lead (Pb in fuel)
- Organic particles (includes soot)
- Sulfates (S in fuel)




Deposit in the extra thoracic/upper trachea-branchial region

Deposit in deeper lung

Pass into the circulatory system

Organic particles (includes soot- carbonaceous material) H, C, O



15 nm < Spherule diameters < 30 nm

Solids – dry carbon particles, commonly known as soot,

SOF – heavy hydrocarbons adsorbed and condensed on the carbon particles, called Soluble Organic Fraction,

SO4 – sulfate fraction, hydrated sulfuric acid H₂SO₄.



Nucleation mode




Accumulation mode

SOF-Polynuclear Aromatic Hydrocarbons (PAH) are hydrocarbons containing two or more benzene rings

Polycyclic Aromatic Hydrocarbons




Naphthalene
C₁₀H₈




Chrysene
C₁₈H₁₂



Pyrene
C₁₆H₁₀




Coronene
C₂₄H₁₂



Ovalene
C₃₂H₁₄

Contrary to gaseous emissions, PM is not a well defined chemical species




2012

- Emissões atmosféricas específicas e resíduos radioativos associados à produção de energia

emissões	
CO2 (g/kWh)	279,13
SO2 (g/kWh)	2,56
NOX (g/kWh)	1,04
Resíduos Radioativos (µg/kWh)	18,75

EMISSÕES ESPECÍFICAS PARQUE TÉRMICO
NOX, SO₂ E PARTICULAS (G/KWH)



[all in mg/km]

RENAULT Clio 1.2 16V 75	M5	1149	Petrol	CO	269	HC	49	NOx	28		
RENAULT Clio 1.5 dCi 88	M5	1461	Diesel	CO	298	HC	23	NOx	155	PM	0.1

low emission zones and the raising of air-quality target



particulate matter (PM)
ozone (O₃)
nitrogen dioxide (NO₂)
sulfur dioxide (SO₂)

Ambient (outdoor air pollution) in both cities and rural areas was estimated to cause **3 million** premature deaths worldwide in 2012

Ambient Air Quality Directive 2008/50/EC

Mean	Limit PM ₁₀ (Particulate Matter)	Limit NO ₂ (Nitrogen Dioxide)
24 h (PM ₁₀) 1 h (NO ₂)	50 µg/m ³ not more than 35 violations /year	200 µg/m ³ not more than 18 violations/year
1 year	40 µg/m ³	40 µg/m ³

PM10 and PM2.5 particulates are easily breathed in (causing lung cancer).

low emission zones and the raising of air-quality target

Avenida da Liberdade

■ **Dados da Estação**

Código:	3075	
Data de início:	1994-01-01	
Tipo de Ambiente:	Urbana	
Tipo de Influência:	Tráfego	
Zona:	Área Metropolitana de Lisboa Norte (a)	
Rua:	Avenida da Liberdade	
Freguesia:	Santo António	
Concelho:	Lisboa	
Coordenadas Gauss Militar (m)	Latitude:	195336
	Longitude:	111902
Coordenadas Geográficas WGS84	Latitude:	38°43'13"
	Longitude:	-9°08'45"
Altitude (m):	44	
Rede:	Rede de Qualidade do Ar de Lisboa e Vale do Tejo	
Instituição:	Comissão de Coordenação e Desenvolvimento Regional de Lisboa e Vale do Tejo	
Contacto:	21 0101 300	

(a) a zona é uma aglomeração

■ **Poluentes**

Poluente	Símbolo	Data de Início	Data de Fim
Monóxido de Azoto	NO	1994-01-01	
Dióxido de Azoto	NO2	1994-01-01	
Óxidos de Azoto	NOx	1994-01-01	
Partículas < 10 µm	PM10	1998-02-01	
Monóxido de Carbono	CO	1994-01-01	



<<

>>

■ **Escolha uma outra estação:**


Escolha uma estação ▼ **OK >>**

■ **Estatísticas:**


Escolha um poluente ▼

▼ **OK >>**

low emission zones and the raising of air-quality target



Air-quality av. Liberdade



1-1-2015
(Thursday)




QualAr

Base de Dados Online sobre a Qualidade de Ar



3-1-2015
(Saturday)



low emission zones and the raising of air-quality target

Estação	Avenida da Liberdade
Inflência	Tráfego
Ambiente	Urbana
Poluente	Dióxido de Azoto (NO2)
Ano	2015

Dados Estatísticos

Parâmetro	Valor Anual (base horária)	Valor Anual (base diária)
Eficiência (%)	98,7%	98,4%
Dados Validados (n.º)	8.644	359
Média (µg/m3)	58,6	58,5
Máximo (µg/m3)	247,3	128,8

Limiar de Alerta

(Decreto-lei n.º 102/2010)

Designação	Valor (µg/m3)	N.º de Excedências
Limiar de Alerta (medido em três horas consecutivas)	400	0

Protecção da Saúde Humana: Base Horária

(Decreto-lei n.º 102/2010)

Designação	Valor (µg/m3)	Excedências Permitidas (horas)	N.º Excedências (horas)
VL	200	18	20

Legenda:

VL - Valor limite: 200 µg/m3.

Protecção da Saúde Humana: Base Anual

(Decreto-lei n.º 102/2010)

Designação	Valor (µg/m3)	Valor Obtido (µg/m3)
VL	40	58,6

low emission zones and the raising of air-quality target

▪ Critérios

Estação:	Avenida da Liberdade
Poluente:	Partículas < 10 µm (PM10)
Ano:	2015

▪ Dados Estatísticos

Parâmetro:	Valor Anual (base horária)	Valor Anual (base diária)
Eficiência (%)	94,3%	93,7%
Dados Validados (n.º)	8.263	342
Média (µg/m3):	36,0	36,0
Máximo (µg/m3):	219,5	118,9

▪ Protecção da Saúde Humana: Base Diária (Decreto-lei n.º 102/2010)

Designação:	Valor (µg/m3)	Excedências Permitidas (dias)	N.º Excedências (dias)
VL	50	35	66


Legenda:
VL - Valor limite: 50 µg/m3.

▪ Protecção da Saúde Humana: Base Anual (Decreto-lei n.º 102/2010)

Designação:	Valor (µg/m3)	Valor obtido (µg/m3)
VL	40	36,0

Legenda:
VL - Valor limite: 40 µg/m3.

400 ppm CO₂ in outdoor environment




$$pV=nRT$$

PTN = Standard pressure and Temperature


Pressure = 100 kPa

Temperature = 298 K




0.7 g/m³ CO₂ in outdoor environment

400 ppm CO₂ in outdoor environment




$$\frac{400 * 10^{-6} \text{ kmol } CO_2 * (12 + 2 * 16) \text{ kg/kmol } CO_2}{1 \text{ kmol air} \cdot \frac{8.314 \frac{\text{kJ}}{\text{kmol air} \cdot \text{K}} * 298 \text{ K}}{100 \text{ kPa}}}$$



0.7 g/m³ CO₂ in outdoor environment

Effect of temperature in real conditions.....





**Stationary combustion
(limits in mg/m³)**



**Mobile combustion
(limits in g/km)**

ANNEX VII

EMISSION LIMIT VALUES FOR DUST

A. Dust emission limit values expressed in mg/Nm³ (O₂ content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

Type of fuel	Rated thermal input (MW)	Emission limit values (mg/Nm ³)
Solid	≥ 500	50 ⁽²⁾
	< 500	100
Liquid ⁽¹⁾	all plants	50
Gaseous	all plants	5 as a rule 10 for blast furnace gas 50 for gases produced by the steel industry which can be used elsewhere

⁽¹⁾ A limit value of 100 mg/Nm³ may be applied to plants with a rated thermal input of less than 500 MWth burning liquid fuel with an ash content of more than 0,06 %.

⁽²⁾ A limit value of 100 mg/Nm³ may be applied to plants licensed pursuant to Article 4(3) with a rated thermal input greater than or equal to 500 MWth burning solid fuel with a heat content of less than 5 800 kJ/kg (net calorific value), a moisture content greater than 45 % by weight, a combined moisture and ash content greater than 60 % by weight and a calcium oxide content greater than 10 %.

B. Dust emission limit values expressed in mg/Nm³ to be applied by new plants, pursuant to Article 4(2) with the exception of gas turbines:

Solid fuels (O₂ content 6 %)

50 to 100 MWth	> 100 MWth
50	30

←
mg/Nm³

- A. NO₂ emission limit values expressed in mg/Nm³ (O₂ content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

Type of fuel:	Limit values ⁽¹⁾ (mg/Nm ³)
Solid ⁽²⁾, ⁽³⁾:	
50 to 500 MWth:	600
>500 MWth:	500
From 1 January 2016	
50 to 500 MWth:	600
>500 MWth:	200
Liquid:	
50 to 500 MWth:	450
>500 MWth:	400
Gaseous:	
50 to 500 MWth:	300
>500 MWth:	200



mg/Nm³

N=normal /standard pressure and temperature

Conversion NO/NO₂
 $= (14+16)/(14+32) \sim 1.53$

⁽¹⁾ Except in the case of the 'Outermost Regions' where the following values shall apply:
 Solid in general: 650
 Solid with < 10 % vol comp: 1 300
 Liquid: 450
 Gaseous: 350

⁽²⁾ Until 31 December 2015 plants of a rated thermal input greater than 500 MW, which from 2008 onwards do not operate more than 2 000 hours a year (rolling average over a period of five years), shall:
 — in the case of plant licensed in accordance with Article 4(3)(a), be subject to a limit value for nitrogen oxide emissions (measured as NO_x) of 600 mg/Nm³;
 — In the case of plant subject to a national plan under Article 4(6), have their contribution to the national plan assessed on the basis of a limit value of 600 mg/Nm₃.
 From 1 January 2016 such plants, which do not operate more than 1 500 hours a year (rolling average over a period of five years), shall be subject to a limit value for nitrogen oxide emissions (measured as NO_x) of 450 mg/Nm³.

⁽³⁾ Until 1 January 2018 in the case of plants that in the 12 month period ending on 1 January 2001 operated on, and continue to operate on, solid fuels whose volatile content is less than 10 %, 1 200 mg/Nm³ shall apply.

A. NO₂ emission limit values expressed in mg/Nm³ (O₂ content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

Type of fuel:	Limit values ⁽¹⁾ (mg/Nm ³)
Solid ⁽²⁾, ⁽³⁾:	
50 to 500 MWth:	600
>500 MWth:	500
From 1 January 2016	
50 to 500 MWth:	600
>500 MWth:	200
Liquid:	
50 to 500 MWth:	450
>500 MWth:	400
Gaseous:	
50 to 500 MWth:	300
>500 MWth:	200

⁽¹⁾ Except in the case of the 'Outermost Regions' where the following values shall apply:

Solid in general: 650
 Solid with < 10 % vol comp: 1 300
 Liquid: 450
 Gaseous: 350

⁽²⁾ Until 31 December 2015 plants of a rated thermal input greater than 500 MW, which from 2008 onwards do not operate more than 2 000 hours a year (rolling average over a period of five years), shall:

- in the case of plant licensed in accordance with Article 4(3)(a), be subject to a limit value for nitrogen oxide emissions (measured as NO₂) of 600 mg/Nm³;
- in the case of plant subject to a national plan under Article 4(6), have their contribution to the national plan assessed on the basis of a limit value of 600 mg/Nm³.

From 1 January 2016 such plants, which do not operate more than 1 500 hours a year (rolling average over a period of five years), shall be subject to a limit value for nitrogen oxide emissions (measured as NO₂) of 450 mg/Nm³.

⁽³⁾ Until 1 January 2018 in the case of plants that in the 12 month period ending on 1 January 2001 operated on, and continue to operate on, solid fuels whose volatile content is less than 10 %, 1 200 mg/Nm³ shall apply.

NO₂@6%O₂



Convert for the same %O₂:

$$xi_{6\%} = xi * \frac{n}{n_{6\%}}$$

Fuel C_xH_y

$$n_{xO_2} = 4.76 * \left[\frac{x + (1 + xO_2)\frac{y}{4}}{1 - 4.76xO_2} \right] + \frac{y}{4} \quad (\text{wet})$$

$$n_{xO_2} = 4.76 * \left[\frac{x + (1 - xO_2)\frac{y}{4}}{1 - 4.76xO_2} \right] - \frac{y}{4} \quad (\text{dry})$$

EN

Official Journal of the European Communities

L 309/17

ANNEX VII

EMISSION LIMIT VALUES FOR DUST

A. Dust emission limit values expressed in mg/Nm³ (O₂ content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

Type of fuel	Rated thermal input (MW)	Emission limit values (mg/Nm ³)
Solid	≥ 500	50 ⁽²⁾
	< 500	100
Liquid ⁽¹⁾	all plants	50
Gaseous	all plants	5 as a rule 10 for blast furnace gas 50 for gases produced by the steel industry which can be used elsewhere

⁽¹⁾ A limit value of 100 mg/Nm³ may be applied to plants with a rated thermal input of less than 500 MWth burning liquid fuel with an ash content of more than 0,06 %.

⁽²⁾ A limit value of 100 mg/Nm³ may be applied to plants licensed pursuant to Article 4(3) with a rated thermal input greater than or equal to 500 MWth burning solid fuel with a heat content of less than 5 800 kJ/kg (net calorific value), a moisture content greater than 45 % by weight, a combined moisture and ash content greater than 60 % by weight and a calcium oxide content greater than 10 %.

B. Dust emission limit values expressed in mg/Nm³ to be applied by new plants, pursuant to Article 4(2) with the exception of gas turbines:

Solid fuels (O₂ content 6 %)

50 to 100 MWth	> 100 MWth
50	30

NO₂@6%O₂



Convert kmol/kmol in mg/Nm³

$$X = \text{fraction} = \frac{n_{NO}}{n_{Total}} * M_{NO} * \frac{1}{\frac{V_{Total}}{n_{Total}}} * 10^3$$

$$X = \text{mg/m}^3 = \frac{\text{kmol}}{\text{kmol}} * \frac{\text{kg}}{\text{kmol}} * \frac{1}{\frac{\text{m}^3}{\text{kmol}}} * 10^3$$


$$\frac{V}{n} = \frac{RT}{p} = \frac{8.314 \frac{\text{kJ}}{\text{kmol}} * 298\text{K}}{100 \text{ kPa}} =$$

$$\frac{8.314 \frac{\text{kJ}}{\text{kmol}} * 298\text{K}}{100 \text{ kNm/m}^3} = 24.8 \text{ m}^3/\text{kmol}$$

Table 1
 EU Emission Standards for Passenger Cars (Category M₁*)

Stage	Date	CO	HC	HC+NOx	NOx	PM	PN
		g/km					
Compression Ignition (Diesel)							
Euro 1 †	1992.07	2.72 (3.16)	-	0.97 (1.13)	-	0.14 (0.18)	-
Euro 2, IDI	1996.01	1.0	-	0.7	-	0.08	-
Euro 2, DI	1996.01 ^a	1.0	-	0.9	-	0.10	-
Euro 3	2000.01	0.64	-	0.56	0.50	0.05	-
Euro 4	2005.01	0.50	-	0.30	0.25	0.025	-
Euro 5a	2009.09 ^b	0.50	-	0.23	0.18	0.005 ^f	-
Euro 5b	2011.09 ^c	0.50	-	0.23	0.18	0.005 ^f	6.0×10 ¹¹
Euro 6	2014.09	0.50	-	0.17	0.08	0.005 ^f	6.0×10 ¹¹

Passenger cars



Truck/bus engines



low emission zones and the raising of air-quality target










Figure 2: Exhaust Gas Re-circulation

Combustion alteration not enough!!!!







**Exhaust gas
aftertreatment**

low emission zones and the raising of air-quality target



**Exhaust gas
aftertreatment**

Exhaust gas aftertreatment gasoline




Gasoline engines (spark-ignition)




TWC-Three Way catalytic converter

Exhaust gas aftertreatment




Cleaning rate or catalytic converter efficiency, e.g.,

$$\frac{NOx_{in} - NOx_{out}}{NOx_{in}} \times 100\%$$



Exhaust gas aftertreatment Diesel




<https://www.youtube.com/watch?v=4VHXnIYUFxc>



<https://www.youtube.com/watch?v=fO1AzO7-bj8>


Rudolf Diesel engines (compression-ignition) → Oxidation catalyst
Particle filter
Selective catalytic reduction

Exhaust gas aftertreatment (with SCR)



Urea solution (~ 5% fuel consumption)

Urea 32.5% wt ($\pm 0.7\%$), density of 1.09 g/cm^3




Exhaust gas aftertreatment (with SCR)



Central Coal Sines \geq 2011

P#11 Poor combustion of C7H14 exercise, 40% theoretical air



The screenshot shows an Excel spreadsheet with the following data:

	A	B	C	D	E	F	G	H	I	J	K	L
4			balanço ao C									
5			7	b+c	7	4 incógnitas		a	b	c	d	
6			balanço ao H									
7			3 equações									
8			balanço ao O									
9			14	2a+2d	0.868436							
10			balanço ao O									
11			8.4	a+2b+c	8.4							
12			Equação que falta									
13			dissociação									
14			$CO_2 + H_2 \leftrightarrow CO + H_2O$									
15			2400K	logKp	0.764							
16				kp	5.807644	$(c*a)/(b*d)$	5.807644					
17			iteração b/c									
18			a	b	c	d						
19			0.233333	1.166667	5.833333	0.200885						

The Goal Seek dialog box is configured as follows:

- Set cell: \$E\$9
- To value: 14
- By changing cell: \$E\$30

A red circle highlights the value 0.868436 in cell E9, and a red arrow points to the value 0.2 in cell E30.

P#12 Poor combustion of C7H14 exercise, 40% theoretical air

iteração b/c		0.034445	
a	b	c	d
1.166911	0.233089	6.766911	5.833179

Goal Seek Status

Goal Seeking with Cell E9 found a solution.

Target value: 14

Current value: 14.00017837



Table: Air pollutant emission standards for coal-fired power plants in China, European Union and the United States (mg/m³)

		China	EU	US
SO ₂	New	100	200	160
	Existing	200/400 ¹	400	160/640 ³
NO _x	New	100	500/200 ²	117
	Existing	100/200 ⁴	500/200 ²	117/160/640 ⁵
PM	New & existing	30	50	22.5
Mercury	New	0.03	-	0.001
	Existing	0.03	-	0.002

1) 400 for four provinces with high-sulphur coal

2) 500 until end 2015; 200 as from 2016

3) 160 for plants built 1997-2005; 640 for plants built 1978-1996

4) 100 for plants built 2004-2011; 200 for plants built before 2004

5) 117 for plants built after 2005; 160 for plants built 1997-2005; 640 for plants built 1978-1996

Source: WRI (2012)

P#12 Consider the molar composition (kmol) of flue gas of a coal furnace with a coal consumption of 90 tonne/h. (power plant with installed power > 500 MW).


$$\text{CO}_2 = 0.052769348$$

$$\text{H}_2\text{O} = 0.028669893$$


$$\text{N}_2 = 0.271015989$$

$$\text{NO} = 8.20116 \times 10^{-5}$$

$$\text{O}_2 = 0.015955756$$




SCR



- Calculate the NO emissions and compare with the limit value imposed by legislation.
- If you use SNCR (selective non catalytic reduction, 80% conversion efficiency), how much NH₃ would you add, and what would be your new NO emissions? Compare with the limit.
- If you use SCR (selective catalytic reduction, 80% conversion efficiency), how much urea would you add, and what would be your new NO emissions? Compare with the limit.
- Discuss on weather to use SNCR or SCR.

Obrigado



Ciências ULisboa

Faculdade
de Ciências
da Universidade
de Lisboa