



PV SYSTEMS SIZING

PV SYSTEM SIZING

- Define load, location, inclination
- Determine irradiation
- Calculate installed power to fulfil load
- Calculate number of modules
- Define system specs
(battery, charge regulator, inverter)

PV SYSTEM SIZING

Example

Stand alone system for the Algarve (37°N)

Equipment	Power	Usage	Daily load (kWh)
3 lights	100 W	3 h/day	0.90
2 lights	60 W	2 h/day	0.24
Fridge	150 W	10 h/day	1.50
Freezer	150 W	10 h/day	1.50
Iron	1000 W	1 h/day	1.00
TV	60 W	4 h/day	0.24
Washing machine	2.2 cycle	Twice week	0.63
Dish washer	1.9 kWh/cycle	Once a day	1.90
Total daily load			7.91

PV SYSTEM SIZING

Step 1

Choose least unfavourable month

Typically December, but could be September for a summer house

Step 2

Choose modules' inclination

Typically latitude + 10°, but could be latitude -10° for a summer house

PV SYSTEM SIZING

Step 3

Determine irradiation (Inclination: $37^\circ + 10^\circ = 47^\circ$)

Month	Monthly irradiation (kWh/m ²)	Daily irradiation (kWh/m ²)
Jan	98.2	3.3
Feb	108.2	3.6
Mar	135.1	4.5
Apr	158.3	5.3
May	169.5	5.6
Jun	166.0	5.5
Jul	184.4	6.1
Aug	197.9	6.6
Sep	163.5	5.4
Oct	144.0	4.8
Nov	109.8	3.7
Dec	98.7	3.3

PV SYSTEM SIZING

Step 3

Calculate irradiation

PSH: **Peak Solar Hours** (hours @ $1 \text{ kW/m}^2 = \text{kW/m}^2/\text{day}$)

Worst month: PSH = 3.3 h/day

Step 4

Define system configuration

Stand alone requires battery


AC appliances require inverter



PV SYSTEM SIZING

Step 5

Calculate installed power



Required power:

$$P_{PV} = \frac{Load}{\eta_{cable} \times \eta_{reg} \times \eta_{bat} \times \eta_{inv}}$$

$$P_{PV} = \frac{7.91kWh / day}{0.69} = 11.5kWh / day$$

Typical

$$\eta_{INV} = 95\%$$

$$\eta_{BAT} = 80\%$$

$$\eta_{REG} = 95\%$$

$$\eta_{CAB} = 95\%$$

PV SYSTEM SIZING

Step 5

Calculate installed power



Required power:

$$P_{PV} = \frac{Load}{\eta_{cable} \times \eta_{reg} \times \eta_{bat} \times \eta_{inv}}$$

$$P_{peak} = \frac{P_{PV}}{PSH}$$

$$P_{PV} = \frac{7.91kWh / day}{0.69} = 11.5kWh / day$$

$$P_{peak} = \frac{11.5kWh / day}{3.3h / day} = 3.48kWp$$

PV SYSTEM SIZING

Step 6

Choose **operating voltage** V_{DC}

Typically multiple of 12V

Determine minimum section of cabling ($\Delta V < 3\%$):

$$s(\text{mm}^2) = \frac{\text{length}(m) \times \text{current}(A)}{56 \times \Delta V}$$

Cheaper (thinner) cables require higher operating voltage.

Let's choose $V_{DC} = 48V$.

PV SYSTEM SIZING

Step 7

Calculate **string length**, from the module voltage, V_m (assume 12V; string with 4 modules)

$$N_s = \frac{V_{DC}}{V_m}$$

Step 8

Calculate **number of strings**

(assume 50Wp module)

$$N_p = \frac{P_{peak}}{P_m \times N_s} = \frac{3.48kWp}{50Wp \times 4} = 17.4 \approx 18$$

PV SYSTEM SIZING

Step 9

Calculate total number of modules,

$$N = N_s \times N_p = 4 \times 18 = 72$$

and its area (assume module area $A_m = 0.4\text{m}^2$)

$$A = N \times A_m = 72 \times 0.4 \approx 30\text{m}^2$$

PV SYSTEM SIZING

Step 10

Determine battery **capacity**

Choose autonomy ($n = 5$ days)

$$C_B = \frac{n \times \text{load}}{\text{depth}}$$

$$C_B = \frac{5 \text{ days} \times \left(\frac{7.91 \text{ kWh / day} \times \eta_{cab}}{V_{DC}} \right)}{0.7} = \frac{5 \times \left(\frac{7.91 \times 0.95}{48} \right)}{0.7}$$

$$C_B = 1118 \text{ Ah}$$

PV SYSTEM SIZING

Step II

Choose **charge regulator** and the **inverter**

Relevant parameters:

- $V_{in} = V_{DC} = 48V$
- $I_{in} = P_{peak} / V_{DC} = 3480 / 48 = 72.5 A$
- $V_{out} = V_{DC} = 48V$
- $P_{out} = (300 + 120 + 150 + 60 + 2200) \sim 3300 W$
assuming that we won't wash and iron at the same time...
- $I_{out} = P_{out} / V_{out} = 3300 / 48 \sim 70 A$

PV SYSTEM SIZING

Design rules

- All strings must have the same voltage
- Minimize module mismatching
- Avoid shading
- Higher inverter efficiencies for high input voltage:
maximize string length

PV SYSTEM SIZING

Design rules

- minimum inverter input voltage $>$
 $>$ MPP voltage @ $+70^{\circ}\text{C}$
- maximum inverter input voltage $<$
 $<$ Open circuit voltage @ -10°C

PV SYSTEM SIZING

Design rules

- Power ratio between 90...110%
(= *input power inverter/nominal power PV generator*)
- Start at **90%**
- **+5%** if annual yield **1200...1600kWh/kWp**
(+10% if annual yield > 1600kWh/kWp)
- **+5%** if ambient temperature **> 30°C**
(+10% if ambient temperature > 40°C)
- **+5%** if single axis **tracking**
(+10% if dual axis tracking)