






- PV generator
 - Mismatch and/or shading
 - Temperature effect
- Energy storage
 - Lead acid batteries
- Power conditioning and control
 - Charge controler
 - Inverter

PV SYSTEMS










In a module, solar cells usually connected in series.

- For a I2V battery:
 - Not optimum irradiation: I6V
 - Fill factor (80%): 20V
 - Each cell (0.6V) x n = 20V
 - n = 33-36 cells in series

When the PV module is not illuminated



Example:

33 cells

Saturation current: 10-10A

Battery: 12.8V


Voltage across each cell: 12.8/33=388mV

Current: 0.32mA (use diode equation)

The battery will discharge during nightime!

More cells in series: lower voltage across each cell, lower reverse current

When the PV module is not illuminated



Example:

33 cells

Saturation current: 10-10A

Battery: 12.8V


Voltage across each cell: 12.8/33=388mV

Current: 0.32mA (use diode equation)

The battery will discharge during nightime!

More cells in series: lower voltage across each cell, lower reverse current
Or use a blocking diode

When **one cell** is not illuminated?




When **one cell** is not illuminated?

Matched solar cells in series:

Cells are in short circuit so:

- Current = Isc
- Voltage = 0V




When **one cell** is not illuminated?

Mismatched solar cells:

Because series connection, current is dominated by 'poor' cell: $I = Isc_2 (< Isc_1)$

The 3 cells are short-circuited so the total voltage is still 0V.

'Poor' cell becomes reverse bias and dissipates 'extra' current. If string is long one will get above breakdown voltage and then hotspot!




When **one cell** is not illuminated?

Matched solar cells, using bypass diode

No effect.

Bypass diodes are reversed bias so no current flow through bypass.




When **one cell** is not illuminated?

Mismatched solar cells, using bypass diode


'Good' cells are forward bias and shaded cell is reverse bias.

Bypass diode of the good cells are reversed biased (no effect).

Bypass diode of the shaded cell is forward bias and conducts current. Voltage drop is only -0.5V, avoiding any hotspots.



Blocking and bypass diodes!






- Module parameters are defined for standard conditions
 - Irradiance: IkW/m²
 - Spectral distribution: AMI.5
 - Cell temperature: 25°C

• V_{oc} sensitive to cell temperature:

$$\frac{dV_{OC}}{dT} = -2.3 \times n \quad (mV / ^{\circ}C)$$


- Normal Operating Cell Temperature (NOCT)
 - Irradiance: 0.8kW/m²
 - Spectral distribution: AMI.5
 - Ambient temperature: 25°C
 - Wind speed: <Im/s
- The **cell temperature** T_c for a given ambient temperature T_a and irradiance $G(kW/m^2)$ is:

$$T_c - T_a = \frac{NOCT - 20}{0.8}G$$




Electrical Specifications


Model	HIT Power 195 or HIP-195BA19	
Rated Power (Pmax) ¹	195 W	
Maximum Power Voltage (Vpm)	55.3 V	
Maximum Power Current (Ipm)	3.53 A	
Open Circuit Voltage (Voc)	68.1 V	
Short Circuit Current (Isc)	3.79 A	
Temperature Coefficient (Pmax)	-0.348% / °C	
Temperature Coefficient (Voc)	-0.189 V / °C	
Temperature Coefficient (Isc)	1.98 mA / °C	
CEC PTC Rating	181.1 W	
Cell Efficiency	19.3%	
Module Efficiency	16.8%	
Watts per Ft. ²	15.6 W	
Maximum System Voltage	600 ∨	
Series Fuse Rating	15 A	
Warranted Tolerance (-/+)	-0% / +10%	




Dependence on Irradiance¹









Mechanical Specifications


Internal Bypass Diodes	4 Bypass Diodes	
Module Area	12.49 Ft. ² (1.16m ²)	
Weight	33.07 Lbs. (15kg)	
Dimensions LxWxH	51.9x34.6x1.8 in. (1319x880x46mm)	
Cable Length -Male/+Female	+Female 30.7/24.8 in. (780/630mm)	
Cable Size / Connector Type	No.12 AWG / MC4™ Locking Connectors	
Static Wind / Snow Load	60PSF (2880Pa) / 39PSF (1867Pa)	
Pallet Dimensions LxWxH	53x35x77 in. (1346x897x1952mm)	
Quantity per Pallet / Pallet Weight	34 pcs. / 1166 Lbs. (530kg)	
Quantity per 20', 40', and 53' Container	340 pcs., 714 pcs., 918 pcs.	

Operating Conditions & Safety Ratings


Ambient Operating Temperature	-4°F to 115°F (-20°C to 46°C) ²	
NOCT	113°F (45°C)	
Hail Safety Impact Velocity	1" hailstone (25mm) at 52 mph (23m/s)	
Fire Safety Classification	Class C	
Safety & Rating Certifications	UL 1703, cUL, CEC	
Limited Warranty	5 Years Workmanship, 20 Years Power Output	

¹STC: Cell Temp. 25°C, AM1.5, 1000W/m² ²Monthly average low and high of the installation site.


Note: Specifications and information above may change without notice.





PV SYSTEMS



Energy stored	Technology	Remarks
Mechanical	Pumped water	PV pumping; or Large-scale storage solution
	Compressed air	Large-scale storage solution
	Flywheel	Under development for small (short) systems
Electromagnetic	Electric current in superconducting ring	Potentially interesting for 'high temperature' superconductors
Chemical	Batteries	Most common for PV
	Hydrogen	Under development







a. Charging process

b. Discharging process

CHARGING

Anode:

$$PbSO_4 + 2H_2O \rightarrow PbO_2 + 4H^+ + SO_4^{2-} + 2e^-$$

Cathode:

$$PbSO_4 + 2e^- \rightarrow Pb + SO_4^{2-}$$
.

DISCHARGING

Anode:

$$PbO_2 + 4H^+ + SO_4^{2-} + 2e^- \rightarrow PbSO_4 + 2 H_2O$$

Cathode:

$$Pb + SO_4^{2-} \rightarrow PbSO_4 + 2e^-$$
.




- Gassing when overcharged, hydrogen ions combine with free electrons and are converted into gaseous hydrogen
- Sulphatation formation of large lead sulphate crystals at the plate
- Stratification non-uniform electrolyte distribution
- Electrode corrosion accelerated at higher temperatures

AVOID OPERATION	TO PREVENT
High voltages during charge	Corrosion, water loss
Low voltages during discharge	Corrosion
Deep Discharge	Sulphation, dendrite growth
Extended period w/o fully carge	Sulphation
High temperature	All ageing processes
Stratification of the electrolyte	Sulphation
Very low carge current	Sulphation

Charging/discharging should be reversible, but there are losses:

- Internal resistance loss (IR²): lower performance for higher currents (also depends on operating temperature)
- Hydrogen escape = energy loss

Overall efficiency: ~90%



Higher C/x means
Higher currents thus
Higher heat losses and
Less useful energy

Battery capacity: C

Battery (dis)charge rate: C/x

 Warm batteries are capable of storing more charge than cold batteries






Figure 3.12 Effect of temperature and discharge rate on available energy from a lead-acid battery.

Lifetime sensitive to depth of discharge



Which is unfortunate for pv systems; either one changes batteries all the time or we need to oversize them!

Lead-acid battery lifetime in cycles vs. depth of discharge per cycle [1].



Charge regulator

- Load disconnect/reconnect voltage
 - User satisfaction vs battery lifetime
 may acommodate warming signal (30' in advance) and/or "manual
 bypass" for special occasions
- End-of-charge/Reposition voltage
 - full charge (high V) vs corrosion and water consumption (low V)
- Protection against reverse current leakage

 Adjusting the load to the PV system point of maximum power




Figure 3.17 Varying a resistive load to track maximum power from a PV array.

Maximum power tracker

(DC/DC converter)

Ensures maximum power transfer to load

$$V_R = \sqrt{P_{\rm max}R}$$





Figure 3.27 Pump and PV I-V characteristics, showing the need for use of MPT.


Inverter

(DC/AC converter)

- Variable frequency for PV pumping systems
- Self-commutating fixed frequency for isolated distribution grid
- Line-commutated fixed frequency for grid connection applications

Inverter







Inverter


• Inverter efficiency: $\eta = P_{AC} / P_{DC}$

To make comparison of different inverters and/or inverters that are operating under different climatic

Efficiency / %

conditions possible:

$$\eta_{\text{EURO}} = 0.03 \times \eta_{5\%} \\
+ 0.06 \times \eta_{10\%} \\
+ 0.13 \times \eta_{20\%} \\
+ 0.10 \times \eta_{30\%} \\
+ 0.48 \times \eta_{50\%} \\
+ 0.20 \times \eta_{100\%}$$




SMART MODULES

Goal: reduce system inefficiencies, maximizing electricity production

Added components increase power electronic costs and risk of failure

SMART MODULES

System inefficiencies



Gap versus Maximum Module


Mismatch from clouds

Not all modules in the same string are receiving the same irradiation.

On average it may reach 15% variation.

SMART MODULES

System inefficiencies




Mismatch from temperature

Not all modules at same temperature. On average it reaches 4-7°C.

Not uniform ageing.


Some modules show faster degradation than others.



SMART MODULES

System inefficiencies

'Smart' modules can increase roof coverage






SMART MODULES

Power optimizers

25kW, Traditional System Design

25kW with Tigo Energy® Smart-Curve



SMART MODULES

Micro-inverters

PV module becomes AC device.

Easier installation.




Figure 1. In conventional string architectures, the poorest performing solar module limits the output of the whole system as the domino effect can knock out all of the string inverters.




Figure 2. An Enecsys micro-inverter-based PV system can prevent the domino effect and reduces the cost per harvested watt by up to 20% over the life of the system.