




Ciências ULisboa

Faculdade
de Ciências
da Universidade
de Lisboa

DISCIPLINA MIEA 2018



Technologies of combustion


Corpo docente

Carla Silva (Teóricas e práticas) /Theory and practice
camsilva@ciencias.ulisboa.pt

P#10 Following table list the results of an experiment of boiler that is used to produce superheated vapour. The boiler is feed by natural gas trough a conventional burner.

- a) The air/fuel ratio**
- b) The higher heating value of the fuel**
- c) Heat transfer to water, assuming that heat loss trough boiler walls are 3% of the lower heating value.**


Fuel rate	150 m³/h
Reactants temperature@ entrance	25°C
Products temperature @exit	227°C
Fuel composition by volume(%)	CH ₄ : 88 H ₂ : 2 CO ₂ : 3 N ₂ : 7
Dry analysis combustion products (%)	O ₂ : 1.1 CO ₂ : 10.8 N ₂ : 88.1




- Maximum heat release, $\max Q_{\text{out}}: T_{\text{out}} = T_{\text{in}}$
- Maximum flame temperature, T_{ad} :

$H_{\text{reag}}(T_{\text{in}}) = H_{\text{prod}}(T_{\text{ad}})$ (constant pressure, e.g. Diesel engine, gas turbine, furnace)


$H_{\text{reag}}(T_{\text{in}}) = H_{\text{prod}}(T_{\text{ad}}) - R(n_{\text{prod}}T_{\text{ad}} - n_{\text{reag}}T_{\text{in}})$ (constant volume, e.g. gasoline engine)



- Ideal stoichiometric combustion



- Real stoichiometric combustion



K is tabulated as a function of temperature for different equilibrium reactions

APÊNDICE 4
CONSTANTES DE EQUILÍBRIO




$\text{H}_2 + 1/2\text{O}_2 \rightleftharpoons \text{H}_2\text{O}$ $\text{CO} + 1/2\text{O}_2 \rightleftharpoons \text{CO}_2$ $\text{CO} + \text{H}_2\text{O} \rightleftharpoons \text{CO}_2 + \text{H}_2$ $\text{OH} + 1/2\text{H}_2 \rightleftharpoons \text{H}_2\text{O}$ $1/2\text{O}_2 + 1/2\text{N}_2 \rightleftharpoons \text{NO}$ $2\text{H} \rightleftharpoons \text{H}_2$ $2\text{O} \rightleftharpoons \text{O}_2$ $2\text{N} \rightleftharpoons \text{N}_2$

$\log_{10} K_p$ com as pressões parciais em atmosferas


$T \text{ (K)}$	$\frac{p_{\text{H}_2\text{O}}}{p_{\text{H}_2} \sqrt{p_{\text{O}_2}}}$	$\frac{p_{\text{CO}_2}}{p_{\text{CO}} \sqrt{p_{\text{O}_2}}}$	$\frac{(p_{\text{H}_2\text{O}})(p_{\text{CO}})}{(p_{\text{H}_2})(p_{\text{CO}_2})}$	$\frac{p_{\text{H}_2\text{O}}}{p_{\text{CH}} \sqrt{p_{\text{H}_2}}}$	$\frac{p_{\text{NO}}}{\sqrt{p_{\text{O}_2}} \sqrt{p_{\text{N}_2}}}$	$\frac{p_{\text{H}_2}}{(p_{\text{H}})^2}$	$\frac{p_{\text{O}_2}}{(p_{\text{O}})^2}$	$\frac{p_{\text{N}_2}}{(p_{\text{N}})^2}$
298	40,048	45,066	-5,018	46,181	-15,171	71,232	81,202	159,600
300	39,786	44,760	-4,974	45,876	-15,073	70,762	80,664	158,578
400	29,240	32,431	-3,191	33,600	-11,142	51,758	58,944	117,408
600	18,633	20,087	-1,454	21,264	-7,210	32,676	37,146	76,162
800	13,289	13,916	-0,627	15,060	-5,243	23,082	26,202	55,488
1000	10,062	10,221	-0,159	11,322	-4,062	17,294	19,612	43,056
1200	7,899	7,764	0,135	8,822	-3,275	13,416	15,208	34,754
1400	6,347	6,014	0,333	7,030	-2,712	10,632	12,054	28,812
1600	5,180	4,706	0,474	5,686	-2,290	8,534	9,684	24,350
1800	4,270	3,693	0,577	4,638	-1,962	6,896	7,836	20,874
2000	3,540	2,884	0,656	3,799	-1,699	5,582	6,356	18,092
2200	2,942	2,226	0,716	3,113	-1,484	4,504	5,142	15,810
2400	2,443	1,679	0,764	2,541	-1,305	3,602	4,130	13,908



Tabela A4.1

Constantes de equilíbrio. (Dados extraídos de Rogers e Mayhew, 1994.) (continua)





More rpm, less combustion time!!!






ppm ☺ !!!!



© 2007 Encyclopædia Britannica, Inc.


$$\phi = \frac{1}{\lambda}$$

How to control combustion to lower at least NO_x emissions?




EGR-Exhaust gas recirculation

Water injection




c) Injecção de água ou vapor de água




d) Estagiamento do ar de combustão

Air introduction in 2 stages



e) Estagiamento do combustível

Air introduction in 2 stages
+fuel introduction in 2 stages




f) "Reburning"

Poor pre-mixtures





g) Pré-misturas pobres




h) "Reburning" + Redução não catalítica selectiva

"Reburning"
+Non-catalytic Selective NO_x reduction

Coal fire power-plants – NO_x control- SNCR- Selective non Catalytic Reduction




Adiabatic Flame Temperature





No pre-mixture

Diesel Combustion Process




Influence of ignition delay on emissions




No pre-mixture


Diesel Combustion Process



Visible particles





Influence of ignition delay on emissions



No pre-mixture

Diesel Combustion Process



Influence of ignition delay on emissions


CA-Crank angle (angulos de cambota)

BTDC-Before Top dead centre (antes do ponto morto superior)

Diesel Engine Emissions : formation, effect of variables and their control



HC emission from CI Engines

- Effect of nozzle sac volume and hole type





Influence of injector nozzle

U.S. Patent Aug. 15, 1978 Sheet 1 of 2 4,106,702



Particles and soot formation

PM1
PM2.5
PM10




Deposit in the extra
thoracic/upper tracheo-
branchial region

Deposit in deeper
lung

Pass into the
circulatory system

Organic particles (includes soot- carbonaceous material) H, C, O



15 nm < Spherule diameters < **30 nm**



Nucleation mode



Accumulation mode

Solids – dry carbon particles, commonly known as soot,


SOF – heavy hydrocarbons adsorbed and condensed on the carbon particles, called Soluble Organic Fraction,

SO4 – sulfate fraction, hydrated sulfuric acid H₂SO₄.

Polycyclic Aromatic Hydrocarbons



Napthalene
C₁₀H₈




Chrysene
C₁₈H₁₂



Pyrene
C₁₆H₁₀



Coronene
C₂₄H₁₂



Ovalene
C₃₂H₁₄


SOF-Polynuclear Aromatic Hydrocarbons (PAH) are hydrocarbons containing two or more benzene rings

2012

– Emissões atmosféricas específicas e resíduos radioativos associados à produção de energia

emissões	
CO ₂ (g/kWh)	279,13
SO ₂ (g/kWh)	2,56
NO _x (g/kWh)	1,04
Resíduos Radioativos (µg/kWh)	18,75

EMISSIONES ESPECÍFICAS PARQUE TÉRMICO
NO_x, SO₂ E PARTICULAS (G/KWH)



[all in mg/km]

RENAULT Clio 1.2 16V 75	M5 1149	Petrol	CO 269	HC 49	NO _x 28	
RENAULT Clio 1.5 dCi 88	M5 1461	Diesel	CO 298	HC 23	NO _x 155	PM 0.1

low emission zones and the raising of air-quality target



particulate matter (PM)
ozone (O₃)
nitrogen dioxide (NO₂)
sulfur dioxide (SO₂)

Ambient (outdoor air pollution) in both cities and rural areas was estimated to cause **3 million** premature deaths worldwide in 2012

Emissions-Outdoor sources

Ambient Air Quality Directive 2008/50/EC

Mean	Limit PM ₁₀ (Particulate Matter)	Limit NO ₂ (Nitrogen Dioxide)
24 h (PM ₁₀) 1 h (NO ₂)	50 µg/m ³ not more than 35 violations /year	200 µg/m ³ not more than 18 violations/year
1 year	40 µg/m ³	40 µg/m ³

PM10 and PM2.5 particulates are easily breathed in (causing lung cancer).

low emission zones and the raising of air-quality target

Avenida da Liberdade

Dados da Estação

Código:	3075
Data de início:	1994-01-01
Tipo de Ambiente:	Urbana
Tipo de Influência:	Tráfego
Zona:	Área Metropolitana de Lisboa Norte (a)
Rua:	Avenida da Liberdade
Freguesia:	Santo António
Concelho:	Lisboa
Coordenadas Gauss Militar (m)	Latitude: 195336 Longitude: 111902
Coordenadas Geográficas WGS84	Latitude: 38°43'13" Longitude: -9°08'45"
Altitude (m):	44
Rede:	Rede de Qualidade do Ar de Lisboa e Vale do Tejo
Instituição:	Comissão de Coordenação e Desenvolvimento Regional de Lisboa e Vale do Tejo
Contacto:	21 0101 300

(a) a zona é uma aglomeração

Poluentes

Poluente	Símbolo	Data de Início	Data de Fim
Monóxido de Azoto	NO	1994-01-01	
Dióxido de Azoto	NO2	1994-01-01	
Óxidos de Azoto	NOx	1994-01-01	
Partículas < 10 µm	PM10	1998-02-01	
Monóxido de Carbono	CO	1994-01-01	




Escolha uma outra estação:

Escolha uma estação ▼ OK >>


Estatísticas:

Escolha um poluente ▼
▼ OK >>


low emission zones and the raising of air-quality target




Air-quality av. Liberdade



1-1-2015
(Thursday)



3-1-2015
(Saturday)



low emission zones and the raising of air-quality target

Estação	Avenida da Liberdade
Inflência	Tráfego
Ambiente	Urbana
Poluente	Dióxido de Azoto (NO ₂)
Ano	2015

Dados Estatísticos

Parâmetro	Valor Anual (base horária)	Valor Anual (base diária)
Eficiência (%)	98,7%	98,4%
Dados Validados (n.º)	8.644	359
Média (µg/m ³)	58,6	58,5
Máximo (µg/m ³)	247,3	128,8

Limiar de Alerta

(Decreto-lei n.º 102/2010)

Designação	Valor (µg/m ³)	N.º de Excedências
Limiar de Alerta (medido em três horas consecutivas)	400	0

Protecção da Saúde Humana: Base Horária

(Decreto-lei n.º 102/2010)

Designação	Valor (µg/m ³)	Excedências Permitidas (horas)	N.º Excedências (horas)
VL	200	18	20

Legenda:

VL - Valor limite: 200 µg/m³.

Protecção da Saúde Humana: Base Anual

(Decreto-lei n.º 102/2010)

Designação	Valor (µg/m ³)	Valor Obtido (µg/m ³)
VL	40	58,6

low emission zones and the raising of air-quality target

■ Critérios

Estação:	Avenida da Liberdade
Poluente:	Partículas < 10 µm (PM10)
Ano:	2015

■ Dados Estatísticos

Parâmetro:	Valor Anual (base horária)	Valor Anual (base diária)
Eficiência (%)	94,3%	93,7%
Dados Validados (n.º)	8.263	342
Média (µg/m³):	36,0	36,0
Máximo (µg/m³):	219,5	118,9

■ Protecção da Saúde Humana: Base Diária (Decreto-lei n.º 102/2010)

Designação:	Valor (µg/m³)	Excedências Permitidas (dias)	N.º Excedências (dias)
VL	50	35	66

Legenda:
VL - Valor limite: 50 µg/m³.

■ Protecção da Saúde Humana: Base Anual (Decreto-lei n.º 102/2010)

Designação:	Valor (µg/m³)	Valor obtido (µg/m³)
VL	40	36,0

Legenda:
VL - Valor limite: 40 µg/m³.

Emissions-Outdoor sources



Stationary combustion
(limits in mg/m³)



Mobile combustion
(limits in g/km)

ANNEX VII

EMISSION LIMIT VALUES FOR DUST

- A. Dust emission limit values expressed in mg/Nm^3 (O_2 content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

Type of fuel	Rated thermal input (MW)	Emission limit values (mg/Nm^3)
Solid	≥ 500	50 ⁽²⁾
	< 500	100
Liquid ⁽¹⁾	all plants	50
Gaseous	all plants	5 as a rule 10 for blast furnace gas 50 for gases produced by the steel industry which can be used elsewhere

⁽¹⁾ A limit value of $100 \text{ mg}/\text{Nm}^3$ may be applied to plants with a rated thermal input of less than 500 MWth burning liquid fuel with an ash content of more than 0.06 %.

⁽²⁾ A limit value of $100 \text{ mg}/\text{Nm}^3$ may be applied to plants licensed pursuant to Article 4(3) with a rated thermal input greater than or equal to 500 MWth burning solid fuel with a heat content of less than 5 800 kJ/kg (net calorific value), a moisture content greater than 45 % by weight, a combined moisture and ash content greater than 60 % by weight and a calcium oxide content greater than 10 %.

- B. Dust emission limit values expressed in mg/Nm^3 to be applied by new plants, pursuant to Article 4(2) with the exception of gas turbines:

Solid fuels (O_2 content 6 %)

50 to 100 MWth	$> 100 \text{ MWth}$
50	30

mg/Nm^3

- A. NO₂ emission limit values expressed in mg/Nm³ (O₂ content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

Type of fuel:	Limit values ⁽¹⁾ (mg/Nm ³)
Solid ⁽²⁾ , ⁽³⁾ :	
50 to 500 MWth:	600
>500 MWth:	500
From 1 January 2016	
50 to 500 MWth:	600
>500 MWth:	200
Liquid:	
50 to 500 MWth:	450
>500 MWth:	400
Gaseous:	
50 to 500 MWth:	300
>500 MWth:	200

⁽¹⁾ Except in the case of the 'Outermost Regions' where the following values shall apply:

Solid in general: 650
Solid with < 10 % vol comp: 1 300
Liquid: 450
Gaseous: 350

⁽²⁾ Until 31 December 2015 plants of a rated thermal input greater than 500 MW, which from 2008 onwards do not operate more than 2 000 hours a year (rolling average over a period of five years), shall:

- in the case of plant licensed in accordance with Article 4(3)(a), be subject to a limit value for nitrogen oxide emissions (measured as NO_x) of 600 mg/Nm³;
- In the case of plant subject to a national plan under Article 4(6), have their contribution to the national plan assessed on the basis of a limit value of 600 mg/Nm³.

From 1 January 2016 such plants, which do not operate more than 1 500 hours a year (rolling average over a period of five years), shall be subject to a limit value for nitrogen oxide emissions (measured as NO_x) of 450 mg/Nm³.

⁽³⁾ Until 1 January 2018 in the case of plants that in the 12 month period ending on 1 January 2001 operated on, and continue to operate on, solid fuels whose volatile content is less than 10 %, 1 200 mg/Nm³ shall apply.

mg/Nm³

N=normal /standard
pressure and
temperature

Conversion NO/NO₂
=(14+16)/(14+32)~1.53

- A. NO_x emission limit values expressed in mg/Nm³ (O₂ content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

Type of fuel:	Limit values ⁽¹⁾ (mg/Nm ³)
Solid ⁽²⁾ , ⁽³⁾ :	
50 to 500 MWth:	600
>500 MWth:	500
From 1 January 2016	
50 to 500 MWth:	600
>500 MWth:	200
Liquid:	
50 to 500 MWth:	450
>500 MWth:	400
Gaseous:	
50 to 500 MWth:	300
>500 MWth:	200

⁽¹⁾ Except in the case of the 'Outermost Regions' where the following values shall apply:

Solid in general: 650
Solid with < 10 % vol comp: 1 300
Liquid: 450
Gaseous: 350

⁽²⁾ Until 31 December 2015 plants of a rated thermal input greater than 500 MW, which from 2008 onwards do not operate more than 2 000 hours a year (rolling average over a period of five years), shall:

- in the case of plant licensed in accordance with Article 4(3)(a), be subject to a limit value for nitrogen oxide emissions (measured as NO₂) of 600 mg/Nm³;
- In the case of plant subject to a national plan under Article 4(6), have their contribution to the national plan assessed on the basis of a limit value of 600 mg/Nm³.

From 1 January 2016 such plants, which do not operate more than 1 500 hours a year (rolling average over a period of five years), shall be subject to a limit value for nitrogen oxide emissions (measured as NO₂) of 450 mg/Nm³.

⁽³⁾ Until 1 January 2018 in the case of plants that in the 12 month period ending on 1 January 2001 operated on, and continue to operate on, solid fuels whose volatile content is less than 10 %, 1 200 mg/Nm³ shall apply.

NO₂@6%O₂



Convert for the same %O₂:

$$xi_{6\%} = xi * \frac{n}{n_{6\%}}$$

Fuel C_xH_y

$$n_{xO_2} = 4.76 * \left[\frac{x + (1 + xO_2)\frac{y}{4}}{1 - 4.76xO_2} \right] + \frac{y}{4} \quad (\text{wet})$$

$$n_{xO_2} = 4.76 * \left[\frac{x + (1 - xO_2)\frac{y}{4}}{1 - 4.76xO_2} \right] - \frac{y}{4} \quad (\text{dry})$$

EN

Official Journal of the European Communities

L 309/17

ANNEX VII

EMISSION LIMIT VALUES FOR DUST

A. Dust emission limit values expressed in mg/Nm³ (O₂ content 6 % for solid fuels, 3 % for liquid and gaseous fuels) to be applied by new and existing plants pursuant to Article 4(1) and 4(3), respectively:

Type of fuel	Rated thermal input (MW)	Emission limit values (mg/Nm ³)
Solid	≥ 500	50 ⁽²⁾
	< 500	100
Liquid ⁽¹⁾	all plants	50
Gaseous	all plants	5 as a rule 10 for blast furnace gas 50 for gases produced by the steel industry which can be used elsewhere

⁽¹⁾ A limit value of 100 mg/Nm³ may be applied to plants with a rated thermal input of less than 500 MWth burning liquid fuel with an ash content of more than 0.06 %.

⁽²⁾ A limit value of 100 mg/Nm³ may be applied to plants licensed pursuant to Article 4(3) with a rated thermal input greater than or equal to 500 MWth burning solid fuel with a heat content of less than 5 800 kJ/kg (net calorific value), a moisture content greater than 45 % by weight, a combined moisture and ash content greater than 60 % by weight and a calcium oxide content greater than 10 %.

B. Dust emission limit values expressed in mg/Nm³ to be applied by new plants, pursuant to Article 4(2) with the exception of gas turbines:

Solid fuels (O₂ content 6 %)

50 to 100 MWth	> 100 MWth
50	30

NO₂@6%O₂



Convert kmol/kmol in mg/Nm³

$$X = \text{fraction} = \frac{n_{NO}}{n_{Total}} * M_{NO} * \frac{1}{\frac{V_{Total}}{n_{Total}}} * 10^3$$


$$X = \text{mg/m}^3 = \frac{\text{kmol}}{\text{kmol}} * \frac{\text{kg}}{\text{kmol}} * \frac{1}{\frac{\text{m}^3}{\text{kmol}}} * 10^3$$

$$\frac{V}{n} = \frac{RT}{p} = \frac{\frac{8.314 \frac{\text{kJ}}{\text{kmol}}}{\text{K}} * 298 \text{K}}{100 \text{ kPa}} = \frac{\frac{8.314 \frac{\text{kJ}}{\text{kmol}}}{\text{K}} * 298 \text{K}}{100 \text{ kNm/m}^3} = 24.8 \text{ m}^3/\text{kmol}$$

Table 1
EU Emission Standards for Passenger Cars (Category M₁*)

Stage	Date	CO	HC	HC+NOx	NOx	PM	PN
		g/km					#/km
Compression Ignition (Diesel)							
Euro 1†	1992.07	2.72 (3.16)	-	0.97 (1.13)	-	0.14 (0.18)	-
Euro 2, IDI	1996.01	1.0	-	0.7	-	0.08	-
Euro 2, DI	1996.01 ^a	1.0	-	0.9	-	0.10	-
Euro 3	2000.01	0.64	-	0.56	0.50	0.05	-
Euro 4	2005.01	0.50	-	0.30	0.25	0.025	-
Euro 5a	2009.09 ^b	0.50	-	0.23	0.18	0.005 ^f	-
Euro 5b	2011.09 ^c	0.50	-	0.23	0.18	0.005 ^f	6.0×10 ¹¹
Euro 6	2014.09	0.50	-	0.17	0.08	0.005 ^f	6.0×10 ¹¹

Passenger cars



Truck/bus engines

low emission zones and the raising of air-quality target





Figure 2: Exhaust Gas Re-circulation




Combustion alteration not enough!!!!



CO₂
H₂O
N₂
CO
HC
NO
NO₂
PM

**Exhaust gas
aftertreatment**

CO₂
H₂O
N₂





**Exhaust gas
aftertreatment**

low emission zones and the raising of air-quality target




**Exhaust gas
aftertreatment**

Exhaust gas aftertreatment gasoline




Gasoline engines (spark-ignition)




TWC-Three Way catalytic converter

Exhaust gas aftertreatment




Cleaning rate or catalytic converter efficiency, e.g.,

$$\frac{NOx_{in} - NOx_{out}}{NOx_{in}} \times 100\%$$



Exhaust gas aftertreatment Diesel





<https://www.youtube.com/watch?v=4VHXnlYUFxc>



<https://www.youtube.com/watch?v=fO1AzO7-bj8>

Rudolf Diesel engines (compression-ignition) → Oxidation catalyst
Particle filter
Selective catalytic reduction

Exhaust gas aftertreatment (with SCR)



Urea solution (~ 5% fuel consumption)

Urea 32.5% wt ($\pm 0.7\%$), density of 1.09 g/cm^3

Exhaust gas aftertreatment (with SCR)



Central Coal Sines $\geq$ 2011

P#11 Consider the molar composition (kmol) of flue gas of a coal furnace with a coal consumption of 90 tonne/h. (power plant with installed power > 500 MW).


$$\text{CO}_2 = 0.052769348$$

$$\text{H}_2\text{O} = 0.028669893$$


$$\text{N}_2 = 0.271015989$$

$$\text{NO} = 8.20116 \times 10^{-5}$$

$$\text{O}_2 = 0.015955756$$




SCR



- Calculate the NO emissions and compare with the limit value imposed by legislation.
- If you use SNCR (selective non catalytic reduction, 80% conversion efficiency), how much NH_3 would you add, and what would be your new NO emissions? Compare with the limit.
- If you use SCR (selective catalytic reduction, 80% conversion efficiency), how much urea would you add, and what would be your new NO emissions? Compare with the limit.
- Discuss on weather to use SNCR or SCR.

P#12 A mixture of methane gas and air at 25°C and 1 atm is burned in a water heater at 100% theoretical air. The mass flow rate of methane is 1.15 kg/h. The exhaust gas temperature was measured to be 500 °C and approximately 1 atm and is subjected to exhaust aftertreatment. The volumetric flow rate of cold water (at 22 °C) to the heater is 4 L/min.

Effect of temperature on the operation of a three-way catalytic converter (Lambda= 1)



- Determine the combustion efficiency.
- Calculate the temperature of the hot water if the heat exchanger were to have an efficiency of 1.0, i.e., perfect heat transfer.
- Consider the following concentrations of emissions at the combustion products:
5000 ppm NO. Estimate the NO exhaust gas emissions in g/h.

Table: Air pollutant emission standards for coal-fired power plants in China, European Union and the United States (mg/m³)

		China	EU	US
SO ₂	New	100	200	160
	Existing	200/400 ¹	400	160/640 ³
NO _x	New	100	500/200 ²	117
	Existing	100/200 ⁴	500/200 ²	117/160/640 ⁵
PM	New & existing	30	50	22.5
Mercury	New	0.03	-	0.001
	Existing	0.03	-	0.002

1) 400 for four provinces with high-sulphur coal

2) 500 until end 2015; 200 as from 2016

3) 160 for plants built 1997-2005; 640 for plants built 1978-1996


4) 100 for plants built 2004-2011; 200 for plants built before 2004

5) 117 for plants built after 2005; 160 for plants built 1997-2005; 640 for plants built 1978-1996

Source: WRI (2012)

The image consists of a large blue square. Inside this square is a white border, which is itself a square. Within the white border is a smaller blue square. The word "Obrigado" is written in white, bold, sans-serif font in the center of the inner blue square.

Obrigado



Ciências ULisboa

Faculdade
de Ciências
da Universidade
de Lisboa